

**To:** Phillips, Pam[phillips.pam@epa.gov]; Garcia, David[Garcia.David@epa.gov]  
**From:** Brown, Jamesr  
**Sent:** Fri 8/7/2015 11:53:23 PM  
**Subject:** FW: Gold King Mine-pH readings from operators

Contact info at the end of these messages.

Sent from my Windows Phone

---

**From:** Restivo, Angela  
**Sent:** 8/7/2015 4:36 PM  
**To:** Brown, Jamesr; Garcia, David; McCasland, Mark; Kirkland, Robert; McCoy, Melinda; Foster, Althea; Crossland, Ronnie; Webster, Susan; Rauscher, Jon; Turner, Philip  
**Subject:** Gold King Mine-pH readings from operators

FYI one update correction on pH at Northstar

**From:** Romero, Nora, NMENV [mailto:Nora.Romero2@state.nm.us]  
**Sent:** Friday, August 07, 2015 4:17 PM  
**To:** Restivo, Angela  
**Subject:** RE: Gold King Mine-pH readings from operators

Clarification from Nathan Yarbrow at Northstar, the pH is 8.7 and at this time the plume hasn't reached the intake site.

**From:** Romero, Nora, NMENV  
**Sent:** Friday, August 07, 2015 12:10 PM  
**To:** 'Restivo, Angela'  
**Subject:** RE: Gold King Mine-pH readings from operators

Hello Angela,

As per your request

Water System No.	Water System Name	Date: August 6 or 7, 2015 pH	Turbidity
------------------	-------------------	---------------------------------	-----------

NM3509824	Aztec Domestic Water System	8.12	18 NTU
NM3510224	Farmington Water System	7.67	4.35 NTU
NM3510524	Morningstar Water Supply System	7.9	28 NTU
NM3520024	Northstar MDWCA		no reading - intake valve has been closed since July 29.
		8.7	

**From:** Restivo, Angela [<mailto:Restivo.Angela@epa.gov>]  
**Sent:** Friday, August 07, 2015 8:34 AM  
**To:** Romero, Nora, NMENV  
**Subject:** RE: Gold King Mine-pH readings from operators

Thank you.

**From:** Romero, Nora, NMENV [<mailto:Nora.Romero2@state.nm.us>]  
**Sent:** Friday, August 07, 2015 9:31 AM  
**To:** Restivo, Angela  
**Cc:** Garcia, David; Brown, Jamesr; Kirkland, Robert; McCasland, Mark; Foster, Althea; Crossland, Ronnie; Skibitski, Thomas, NMENV  
**Subject:** RE: Gold King Mine-pH readings from operators

Angela

I will work on that

**From:** Restivo, Angela [<mailto:Restivo.Angela@epa.gov>]  
**Sent:** Friday, August 07, 2015 8:29 AM  
**To:** Romero, Nora, NMENV  
**Cc:** Garcia, David; Brown, Jamesr; Kirkland, Robert; McCasland, Mark; Foster, Althea; Crossland, Ronnie; Skibitski, Thomas, NMENV  
**Subject:** Gold King Mine-pH readings from operators

Nora,

Can you get the pH levels from each of the systems on the river? This information would be helpful in our flow and water quality calculations.

Thanks.

Angela Restivo

Compliance Officer

Drinking Water Section

U.S. EPA Region 6

1445 Ross Ave (6WQ-SD)

Dallas, Texas 75202-2733

phone: 214-665-7123